



**BUREAU
VERITAS**

Certificate of Product Conformity

BVI.DOA.20.IND.060.49.CPC.01

Job Description : Conformity assessment of a product
Product Name : **Polyethylene (PE) Pipes for Water Supply, Drainage and Sewerage under pressure**
Product range : From 110 – 800 mm
Manufacturer : Qatar National Plastic Factory W.L.L ('QPlast)
Date of Inspection : 14/03/2020 - 06/08/2020

Scope of work:

1. Review Quality Plan
2. Review QA/QC Procedures
3. Review Personnel Competency
4. Carry out a site visit during production
5. Review test equipment & calibration record
6. Witnessing Extrusion Process and Raw Material Test
7. Witnessing Dimensional, Mechanical Strength & Pressure Test
8. Final Marking Verification, Documents Review

Documents Referenced:

1. ISO 4427-1:2019
2. ISO 4427-2:2019

Result of Inspection: The product of Polyethylene (PE) Pipes for Water Supply, Drainage and Sewerage under pressure range from 110 – 800mm, manufactured and tested by Qatar National Plastic Factory W.L.L (QPlast) have been evaluated and found in conformity against the requirements of the standard ISO 4427:2019 Part 1 & 2

This note is issued further to an inspection whose duration and scope were limited by the terms and conditions of the contract with BV principal. This note is NOT an indication that the item(s) is (are) fit for any specific purpose and does not release the manufacturer, supplier and any party from their respective duty, guarantee, obligation and/or indemnity relating to, without limitation, patents, workmanship, materials, safety, performance in operation and /or reliability.

This Certificate is valid for 1 Year from the date of issue.

Survey Carried out by : Annaparaju Kanda & Siva Sankar Reddy Mukku
Certificate issued by : Siva Sankar Reddy Mukku
Date of issue : 26/08/2020
Certificate Number : 001/2020
Inspection Center : Doha, Qatar

