



Certificate of Compliance

This certificate is issued for the following:

Polyethylene Pipe for Underground Fire Protection Service

<i>Product Designation</i>	<i>O.D., Pipe Size, mm.</i>	<i>Pressure Rating, psi (kPa)</i>	<i>Remarks</i>
SDR11 Pipe	63, 90, 110, 160, 200, 250, 315, 355	150 (1030)	a
SDR9 Pipe	63, 90, 110, 160, 200, 250, 315, 355	200 (1375)	a

Remarks:

a. Pipe and fittings may be directly connected together by the butt fusion process. Manufacturer's fusion instructions must be strictly followed for a proper fusion joint.

Prepared for:

Qatar National Plastic Factory WLL
New Industrial Area, Zone 81, Str. 4, Bldg 135
PO Box 5615, Doha
Qatar

Manufactured at:

Qatar National Plastic Factory WLL
New Industrial Area, Zone 81, Str. 4, Bldg 135
PO Box 5615, Doha
Qatar

FM Approval Standard Class: 1613 (February 2017)

Approval Identification: 3062206

Approval Granted: April 2, 2021

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
VP, Manager - Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group